



Gas safety record

To confirm the validity of the gas operative please contact the gas registration body. This inspection is for gas safety purposes only in accordance with the Gas Safety (Installation and Use) Regulations. Flues were inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and lining has not been carried out.

Inspection Undertaken
GAS SAFE
ACOP

Cert. No. **14242**



Registered Business Details
Gas Operative Graham Howard (print name)
Operative Licence No. H012397
Company SMH Products
Address carenton rd
 Cardiff
Postcode CF316Y Tel No. 02920 780790

Unit Details
Model Decon
Serial Number 20181001
Location Cardiff

Customer Details
Name Kusten vorland Tel. No.
Address
Postcode Contact
Order No. SMH Order No.
SMH Invoice No.

APPLIANCE DETAILS

Unit Details	Appliance Type	Make	Model	Appliance Inspected Yes / No	Flue Type OF / RS / FL
Decon	water heater	marco	elle	YES	OF

INSPECTION DETAILS

Operating pressure in mbar or heat input in kW	Initial combustion analyser reading (if applicable)	Final combustion analyser reading (if applicable)	Safety device(s) correct operation Yes / No / NA	Ventilation provision satisfactory Yes / No	Visual condition of chimney/termination satisfactory Yes/No/NA	Flue performance checks Pass / Fail / NA	Appliance serviced Yes / No	Appliance safe to use Yes / No	Approved CO fitted Yes / No / NA	Is CO alarm in date Yes / No / NA	Testing of CO alarm satisfactory Yes / No / NA
32	—	00018	YES	YES	YES	Pass	NO	YES	/	/	/

EFFECT(S) IDENTIFIED

Regulator out of Date

Flue Damaged

If Warning/Advice Notice issued insert

EMEDIAL ACTION TAKEN

Replaced Regulator

Replaced flue

Cylinder/final connection hoses to DCU satisfactory Yes / No
 Gas installation pipework (visual inspection) satisfactory Yes / No
 Gas tightness test satisfactory Yes / No / NA
 ECV accessible and operating Yes / No
 LPG regulator operating pressure (mbar) 39
 LPG regulator lock-up pressure (mbar) 41

Safety Record issued by: Graham Howard
 Print Name:
 Received by:
 Date: 16/3/17